

# BETO direct / indirect power

free standing U-shape

074-6954518R



Project / Type

Notes

Count / Date



## General

Floor , Standing  
black , RAL 9005 <sup>1</sup>  
Reflector chrome  
IP20  
indirect 6630 lm  
direct 2020 lm  
total 8650 lm

## LED

3000 K  
CRI  $\geq$  80  
L90 / 50000 h  
initial MacAdam  $\leq$  3 SDCM  
MR 0.56  
MDER 0.51

## Optical

Reflector  
asymmetric  
UGR  $\leq$  13  
PstLM  $\leq$  1.0 <sup>2</sup>  
SVM  $\leq$  0.4 <sup>2</sup>

## Electrical


touch DIM on pole  
220-240 V  
system 66 W  
system 131 lm/W<sup>3</sup>  
PC1

## Physical


U-shape  
length 1055 mm  
width 42 mm  
height 2100 mm  
11.7 kg

<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)  
<sup>3</sup> incl. consideration of optical losses, internal control unit losses  
& operating device efficiency

## Light distribution



## Product drawing



## Installation instructions



[074-6954518R] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of XAL GmbH apply.  
© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com

11.04.2025

# BETO direct / indirect power

free standing U-shape

074-6954518R



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF

LMF × RSMF × LLMF × LSF

MF

Maintenance Factor

LMF<sup>a</sup>

Luminaire Maintenance Factor

RSMF<sup>a</sup>

Room Surface Maintenance Factor

LLMF

Lamp Lumens Maintenance Factor

LSF

Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	13
B13	17
B16	21
B20	27
C10	21
C13	28
C16	35
C20	45

