

# VELA 600 direct / indirect power

suspended  
073-145563XO



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_



IP 40 X-PERT

**General**

Ceiling , Suspended \_\_\_\_\_

special colours \_\_\_\_\_

IP40 \_\_\_\_\_

indirect 2850 lm \_\_\_\_\_

direct 6280 lm \_\_\_\_\_

total 9130 lm \_\_\_\_\_

**LED**

4000 K \_\_\_\_\_

CRI  $\geq$  80 \_\_\_\_\_

L90 / 50000 h \_\_\_\_\_

initial MacAdam  $\leq$  3 SDCM \_\_\_\_\_

MR 0.72 \_\_\_\_\_

MDER 0.66 \_\_\_\_\_

**Optical**

Opal \_\_\_\_\_

opal (lambertsch) \_\_\_\_\_

PstLM  $\leq$  1.0 <sup>1</sup> \_\_\_\_\_

SVM  $\leq$  0.4 <sup>1</sup> \_\_\_\_\_

**Electrical**

DALI-2 \_\_\_\_\_

220-240 V \_\_\_\_\_

system 68 W \_\_\_\_\_

system 134 lm/W<sup>2</sup> \_\_\_\_\_

PC1 \_\_\_\_\_

1 DALI Addr. \_\_\_\_\_

**Physical**

rod 1000 mm \_\_\_\_\_


diameter 600 mm \_\_\_\_\_

height 87 mm \_\_\_\_\_

6.1 kg \_\_\_\_\_

Round luminaire housing in aluminium, rolled profile, seamlessly welded; surface special colours powder coated; highly reflective coating for improved efficiency; suspended luminaire with adjustable pendant rod mounting (chrome) 1000mm, feed in rod; completely homogeneously illuminated, satinised PMMA cover; direct / indirect radiation characteristic for additional accentuation of the ceiling; light colour 4000 K; binning initial MacAdam  $\leq$  3 SDCM; CRI  $\geq$  80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; canopy with 2 cable openings and plug-in terminal for through wiring; degree of protection IP40; PC1; 220-240 V; internal wiring in light halogen free; incl. DALI-2 converter; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

## Light distribution



## Product drawing



<sup>1</sup> Value of containing product at full load (undimmed)  
<sup>2</sup> FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

### Installation instructions

### Lighting calculator

VELA 600 direct / indirect  
power  
suspended  
073-145563XO



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.91	0.9
LSF	1	1	1	1	1

MF

LMF × RSMF × LLMF × LSF

MF

Maintenance Factor

LMF<sup>a</sup>

Luminaire Maintenance Factor

RSMF<sup>a</sup>

Room Surface Maintenance Factor

LLMF

Lamp Lumens Maintenance Factor

LSF

Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	10
B13	13
B16	16
B20	21
C10	16
C13	21
C16	26
C20	35