

# VELA 600 direct / indirect power

suspended  
073-14546170



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_



IP 40 X-PERT

**General**

Ceiling , Suspended \_\_\_\_\_

white , RAL 9010 <sup>1</sup> \_\_\_\_\_

IP40 \_\_\_\_\_

indirect 1970 lm \_\_\_\_\_

direct 4350 lm \_\_\_\_\_

total 6320 lm \_\_\_\_\_

**LED**

4000 K \_\_\_\_\_

CRI  $\geq$  80 \_\_\_\_\_

L90 / 50000 h \_\_\_\_\_

initial MacAdam  $\leq$  3 SDCM \_\_\_\_\_

MR 0.72 \_\_\_\_\_

MDER 0.66 \_\_\_\_\_

**Optical**

Opal \_\_\_\_\_

opal (lambertsch) \_\_\_\_\_

PstLM  $\leq$  1.0 <sup>2</sup> \_\_\_\_\_

SVM  $\leq$  0.4 <sup>2</sup> \_\_\_\_\_

**Electrical**

non DIM \_\_\_\_\_

220-240 V \_\_\_\_\_

system 45 W \_\_\_\_\_

system 140 lm/W<sup>3</sup> \_\_\_\_\_

PC1 \_\_\_\_\_

**Physical**

rod 1000 mm \_\_\_\_\_


diameter 600 mm \_\_\_\_\_

height 87 mm \_\_\_\_\_

6.1 kg \_\_\_\_\_

Round luminaire housing in aluminium, rolled profile, seamlessly welded; surface white powder coated; highly reflective coating for improved efficiency; suspended luminaire with adjustable pendant rod mounting (chrome) 1000mm, feed in rod; completely homogeneously illuminated, satinised PMMA cover; direct / indirect radiation characteristic for additional accentuation of the ceiling; light colour 4000 K; binning initial MacAdam  $\leq$  3 SDCM; CRI  $\geq$  80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; canopy with 2 cable openings and plug-in terminal for through wiring; degree of protection IP40; PC1; 220-240 V; internal wiring in light halogen free; incl. converter, non dimmable; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

## Light distribution



## Product drawing



<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)  
<sup>3</sup> FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

## Installation instructions



## Lighting calculator





Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	7
B13	9
B16	11
B20	14
C10	12
C13	16
C16	19
C20	24