

# VELA 450 direct / indirect power

suspended  
073-1244537K



Project / Type	
Notes	
Count / Date	



## General

Ceiling , Suspended  
white , RAL 9010 <sup>1</sup>  
IP40  
indirect 767 lm  
direct 1960 lm  
total 2730 lm

## LED

3000 K  
CRI  $\geq 80$   
L90 / 50000 h  
initial MacAdam  $\leq 3$  SDCM  
MR 0.54  
MDER 0.49

## Optical

Microprismatic  
microprismatic  
UGR  $< 16$  ,  $\geq 65^\circ$   $< 3000$  cd/m<sup>2</sup>  
PstLM  $\leq 1.0$  <sup>2</sup>  
SVM  $\leq 0.4$  <sup>2</sup>

## Electrical


DALI-2  
220-240 V  
system 21.1 W  
system 129 lm/W<sup>3</sup>  
PC1  
1 DALI Addr.

## Physical


cable 1500 mm  
diameter 450 mm  
height 87 mm  
3.8 kg

<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)  
<sup>3</sup> FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

## Light distribution



## Product drawing



## Installation instructions



## Lighting calculator



VELA 450 direct / indirect  
power  
suspended  
073-1244537K



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	13
B13	20
B16	24
B20	30
C10	26
C13	40
C16	48
C20	60

