

VELA 600 direct / indirect power

suspended
073-125563XO



Project / Type _____

Notes _____

Count / Date _____



IP 40 X-PERT

General

Ceiling , Suspended _____

special colours _____

IP40 _____

indirect 2850 lm _____

direct 6280 lm _____

total 9130 lm _____

LED

4000 K _____

CRI \geq 80 _____

L90 / 50000 h _____

initial MacAdam \leq 3 SDCM _____

MR 0.72 _____

MDER 0.66 _____

Optical

Opal _____

opal (lambertsch) _____

PstLM \leq 1.0 ¹ _____

SVM \leq 0.4 ¹ _____

Electrical

DALI-2 _____

220-240 V _____

system 68 W _____

system 134 lm/W² _____

PC1 _____

1 DALI Addr. _____

Physical

cable 1500 mm _____


diameter 600 mm _____

height 87 mm _____

5.8 kg _____

¹ Value of containing product at full load (undimmed)
² incl. consideration of optical losses, internal control unit losses & operating device efficiency

Light distribution



Product drawing



Installation instructions



Lighting calculator



VELA 600 direct / indirect power

suspended
073-125563XO



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	10
B13	13
B16	16
B20	21
C10	16
C13	21
C16	26
C20	35

