

TASK S linear direct / indirect soft

suspended system
059-5756137K



Project / Type _____

Notes _____

Count / Date _____



General

Ceiling , Suspended _____

white , RAL 9010 ¹ _____

IP20 _____

indirect 521 lm _____

direct 3040 lm _____

total 3560 lm _____

LED

4000 K _____

CRI ≥ 90 _____

L90 / 50000 h _____

initial MacAdam ≤ 3 SDCM _____

R_g: 96 , R_f: 90 , R_{t(1-15)}: 87 _____

MR 0.75 _____

MDER 0.68 _____

Optical

Microprismatic _____

microprismatic _____

UGR < 19 , ≥65° <3000 cd/m² _____

PstLM ≤ 1.0 ² _____

SVM ≤ 0.4 ² _____

Electrical

DALI-2 _____

220-240 V _____

system 29.2 W _____

system 122 lm/W³ _____

PC1 _____

1 DALI Addr. _____

Physical


length 1748 mm _____

width 180 mm _____

height 34 mm _____

4.8 kg _____

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)
³ FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

Installation instructions



Lighting calculator

