

TASK S direct / indirect soft

suspended

059-525613XK



Project / Type
Notes
Count / Date



General

Ceiling , Suspended
special colours
IP20
indirect 521 lm
direct 3040 lm
total 3560 lm

LED

4000 K
CRI ≥ 90
L90 / 50000 h
initial MacAdam ≤ 3 SDCM
R _g : 96 , R _f : 90 , R ₍₁₋₁₅₎ : 87
MR 0.75
MDER 0.68

Optical

Microprismatic
microprismatic
UGR < 19 , $\geq 65^\circ$ <3000 cd/m ²
P _{stLM} ≤ 1.0 ¹
SVM ≤ 0.4 ¹

Electrical


DALI-2
220-240 V
system 29.2 W
system 122 lm/W ²
PC1
1 DALI Addr.

Physical


cable 1500 mm
length 1748 mm
width 180 mm
height 34 mm
5.1 kg

¹ Value of containing product at full load (undimmed)
² FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

Light distribution



Product drawing



Installation instructions



Lighting calculator



TASK S direct / indirect soft

suspended

059-525613XK



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.97	0.95	0.93	0.92
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	18
B13	23
B16	28
B20	35
C10	30
C13	38
C16	46
C20	58

