

TASK sensor direct / indirect soft

free standing U-shape

059-2943078Z



Project / Type

Notes

Count / Date



General

Floor , Standing

black , RAL 9005 ¹

IP20

indirect 3350 lm

direct 4100 lm

total 7450 lm

LED

3000 K

CRI \geq 90

L90 / 50000 h

initial MacAdam \leq 3 SDCM

R_g: 96 , R_f: 90 , R_{t(1-15)}: 90

MR 0.61

MDER 0.56

Optical

Microprismatic

microprismatic

UGR < 19

P_{stLM} \leq 1.0 ²

SVM \leq 0.4 ²

Electrical

ESSENTIAL sensor (brightness & presence)

220-240 V

system 71 W

system 105 lm/W³

PC1

Physical

U-shape

length 800 mm

width 320 mm


height 1920 mm

12.5 kg


¹ RAL code ² Value of containing product at full load (undimmed)

³ FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

Light distribution



Product drawing



TASK sensor direct / indirect soft

free standing U-shape
059-2943078Z



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.97	0.95	0.93	0.92
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	8
B13	10
B16	13
B20	16
C10	13
C13	17
C16	22
C20	27

