

MINIMAL 100 high lumen

trimless

052-33M8637G



Project / Type

Notes

Count / Date



General

Ceiling , Recessed

white , RAL9016 ¹

2710 lm/m

IP20

6350 lm

LED

4000 K

CRI \geq 80

L90 / 50000 h

photobio. safety RG 0 - no Risk

initial MacAdam \leq 3 SDCM

MR 0.72

MDER 0.66

Optical

Microprismatic

microprismatic

UGR < 19

PstLM \leq 1.0 ²

SVM \leq 0.4 ²

Electrical

DALI-2

system 55 W

PC1 220-240V

system 115 lm/W³

1 DALI Addr.

23 W/m

Physical

trimless

length 2348 mm

width 102 mm

height 82 mm

8.2 kg

Cutout

length 2351 mm

width 106 mm

min. ceiling thickness 8 mm


max. ceiling thickness 25 mm

recessed depth 106 mm


¹ RAL code ² Value of containing product at full load (undimmed)

³ incl. optical losses and the efficiency of the operating device (converter)

Light distribution



Product drawing



Installation instructions



Lighting calculator



MINIMAL 100 high lumen

trimless

052-33M8637G



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	7
B13	10
B16	12
B20	14
C10	10
C13	20
C16	24
C20	28

Mounting accessories

CONCRETE INSTALLATION HOUSING

TYPE	L-W-H (MM)	ARTICLE NUMBER(S)
2407 mm	2407-116-94	036-05236

