

# FRAME 100 high lumen

trim

052-43M353GH



Project / Type

Notes

Count / Date



### General

Ceiling , Recessed

grey , RAL 9006 <sup>1</sup>

IP20

2510 lm

2870 lm/m

### LED

3000 K

CRI ≥ 80

L90 / 50000 h

initial MacAdam ≤ 3 SDCM

MR 0.54

MDER 0.49

### Optical

High Performance Opal

opal (lambertsch)

PstLM ≤ 1.0 <sup>2</sup>

SVM ≤ 0.4 <sup>2</sup>

### Electrical

DALI-2

220-240 V

system 20.6 W

system 122 lm/W<sup>3</sup>

PC1

1 DALI Addr.

24 W/m

### Physical

trim

length 896 mm

width 120 mm

height 82 mm

3.6 kg

### Cutout

length 884 mm


width 108 mm

min. ceiling thickness 8 mm


max. ceiling thickness 25 mm

recessed depth 108 mm

### Light distribution



### Product drawing



# FRAME 100 high lumen

trim

052-43M353GH



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	20
B13	26
B16	32
B20	41
C10	33
C13	43
C16	53
C20	68

## Mounting accessories

### CONCRETE INSTALLATION HOUSING

L-W-H (MM)	ARTICLE NUMBER(S)
935-116-94	036-05096

