



Project / Type

Notes

Count / Date



General
Ceiling / Wall , Semi-Recessed
white , RAL 9010 <sup>1</sup>
front IP40 , back IP20
3520 lm
1930 lm/m

LED
3000 K
CRI ≥ 80
L90 / 50000 h
initial MacAdam ≤ 3 SDCM
MR 0.54
MDER 0.49

Optical
Jut-Out
opal (lambertsch)
PstLM ≤ 1.0 <sup>2</sup>
SVM ≤ 0.4 <sup>2</sup>


Electrical
DALI-2
220-240 V
system 28.6 W
system 123 lm/W <sup>3</sup>
PC1
1 DALI Addr.
16 W/m

Physical
length 1835 mm
width 89 mm
height 38 mm
5.4 kg

Cutout
length 1843 mm
width 70 mm
min. ceiling thickness 12.5 mm
recessed depth 13 mm

<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)  
<sup>3</sup> incl. consideration of optical losses, internal control unit losses  
& operating device efficiency

Light distribution



Product drawing



Installation instructions



# LENO jut-out

semi-recessed  
051-8516537J



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	18
B13	24
B16	30
B20	37
C10	31
C13	40
C16	51
C20	62

## Other accessories

### DISMOUNTING TOOL

TYPE	ARTICLE NUMBER(S)
vacuum cup	086-30000

