

# BATWING

MOVE IT 25 S  
050-1214538B




Project / Type	
Notes	
Count / Date	



Linear light inset made of aluminium; surface anodised black; light inset can be installed and moved without tools by means of magnetic holders+locking; flush with profile system; power supplied via MOVE IT system track profile; hot plug protection; with specially computed BATWING lens for wide light distribution; passive cooling of the LEDs through improved heat sink geometry; with CSP (Chip-Scale-Packaging) technology for maximum efficiency; light colour 3000 K; binning initial MacAdam  $\leq 3$  SDCM; CRI  $\geq 90$ ; min. 80% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC3; 48 V; DALI single control; flicker-free visual comfort through analogue current control (minimum value 1%); light source not replaceable;

## Light distribution



## Product drawing



### General

Ceiling / Wall , Track	
black , RAL 9005 <sup>1</sup>	
IP20	
2200 lm	
optical inset 148 lm/W <sup>2</sup>	

### LED

3000 K	
CRI $\geq 90$	
L80 / 50000 h	
initial MacAdam $\leq 3$ SDCM	
R <sub>g</sub> : 99 , R <sub>r</sub> : 91 , R <sub>f(1-15)</sub> : 89	
MR 0.61	
MDER 0.55	

### Optical

batwing	
PstLM $\leq 1.0$ <sup>3</sup>	
SVM $\leq 0.4$ <sup>3</sup>	

### Electrical

DALI-2 single control	
48 V	
fixture 21.3 W	
optical inset 14.9 W	
PC3	
1 DALI Addr.	

### Physical

length 1205 mm	
width 25 mm	
height 20 mm	
0.45 kg	

<sup>1</sup> RAL code  
<sup>2</sup> OPTICAL INSET: incl. consideration of optical losses  
<sup>3</sup> Value of containing product at full load (undimmed)

## Installation instructions





Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.96	0.92	0.87	0.83	0.8
LSF	1	1	1	1	1

MF

MF

LMF<sup>a</sup>

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF<sup>a</sup>

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.