




Project / Type _____

Notes _____

Count / Date _____



Cylindrical, decorative-graphic light inset made of aluminium and satinised PMMA for homogeneous illumination; surface anodised black; light inset can be installed and moved without tools by means of magnetic holders+locking; suitable for two MOVE IT 25 S profiles as well as one MOVE IT 25 S profile (axial arrangement); holders 360° rotatable; power supplied via MOVE IT system track profile; hot plug protection; passive cooling of the LEDs through improved heat sink geometry; with CSP (Chip-Scale-Packaging) technology for maximum efficiency; light colour: tunable white diodes (1800-4000 K); binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC3 48V; photobiological safety according to IEC 62471 risk group RG 0 - no Risk; DALI single control; flicker-free visual comfort through analogue current control (minimum value 1%); light source replaceable by an authorized professional;




General	
Ceiling , Track	_____
rotation 360°	_____
black , RAL9005 ¹	_____
1080 lm/m	_____
IP20	_____
975 lm	_____

LED	
tunable white	_____
1800 K - 4000 K	_____
CRI ≥ 80	_____
L90 / 50000 h	_____
photobio. safety RG 0 - no Risk	_____
initial MacAdam ≤ 3 SDCM	_____
MR 0.72	_____
MDER 0.66	_____


Electrical	
DALI-2 DT8	_____
7.9 W	_____
PC3 48V	_____
123 lm/W	_____
1 DALI Addr.	_____
9 W/m	_____

Physical	
length 910 mm	_____
width 33 mm	_____
height 33 mm	_____
0.4 kg	_____

Light distribution



Product drawing



¹ RAL code

Installation instructions



Lighting calculator





Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.9	0.9
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.