

SASSO 100 round downlight

suspended
048-34204111W



Project / Type _____

Notes _____

Count / Date _____



General

Ceiling , Suspended _____

black , RAL 9005 ¹ _____

Inner colour black _____

IP20 _____

1540 lm _____

LED

2700 K _____

CRI \geq 90 _____

L80 / 50000 h _____

initial MacAdam \leq 2 SDCM _____

R_g: 99 , R_r: 91 , R_{t(1-15)}: 89 _____

MR 0.53 _____

MDER 0.48 _____

Optical

wide flood _____

beam angle 65° _____

$\geq 65^\circ$ <1500 cd/m² _____

PstLM \leq 1.0 ² _____

SVM \leq 0.4 ² _____

Electrical

non DIM _____

220-240 V _____

system 20.2 W _____

system 76 lm/W³ _____

PC1 _____

Physical


diameter 100 mm _____

height 115 mm _____

1.3 kg _____

¹ RAL code ² Value of containing product at full load (undimmed)
³ FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

Light distribution



Product drawing



Installation instructions



Lighting calculator



SASSO 100 round downlight

suspended
048-34204111W



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.96	0.92	0.88	0.85	0.81
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B13	40
B16	50
B20	62
C13	67
C16	85
C20	104

Optical accessories

HONEYCOMB LOUVER

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
jet black	50	007-1965598

