

# SASSO 60 square downlight

ceiling

048-30104177F



Project / Type

Notes

Count / Date



### General

Ceiling , Surface

white , RAL9016/white <sup>1</sup>

Inner colour white

IP20

851 lm

### LED

2700 K

CRI ≥ 90

L80 / 50000 h

initial MacAdam ≤ 2 SDCM

R<sub>g</sub>: 99 , R<sub>r</sub>: 91 , R<sub>t(1-15)</sub>: 89

MR 0.53

MDER 0.48

### Optical

flood

beam angle 44°

UGR < 19

PstLM ≤ 1.0 <sup>2</sup>

SVM ≤ 0.4 <sup>2</sup>

### Electrical

non DIM

system 10.4 W

PC1 220-240V

system 82 lm/W<sup>3</sup>

inset 97 lm/W<sup>4</sup>

### Physical

length 72 mm

width 72 mm

height 108 mm


0.5 kg

<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)

<sup>3</sup> incl. optical losses and the efficiency of the operating device (converter)

<sup>4</sup> incl. optical losses

### Light distribution



### Product drawing



### Installation instructions



### Lighting calculator



# SASSO 60 square downlight

ceiling  
048-30104177F



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.96	0.92	0.88	0.85	0.81
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	62
B13	81
B16	98
B20	124
C10	104
C13	137
C16	168
C20	209

