

SASSO 60 square downlight

ceiling

048-30106174F



Project / Type

Notes

Count / Date



General

Ceiling , Surface

white , RAL9016/matt silver ¹

Inner colour matt silver

IP20

974 lm

LED

4000 K

CRI \geq 90

L80 / 50000 h

initial MacAdam \leq 2 SDCM

R_g: 97 , R_r: 90 , R_{t(1-15)}: 89

MR 0.81

MDER 0.74

Optical

flood

beam angle 42°

UGR $<$ 19 , $\geq 65^\circ$ $<$ 1500 cd/m²

PstLM \leq 1.0 ²

SVM \leq 0.4 ²

Electrical

non DIM

system 10.4 W

PC1 220-240V

system 94 lm/W³

inset 111 lm/W⁴

Physical

length 72 mm

width 72 mm

height 108 mm


0.5 kg

¹ RAL code ² Value of containing product at full load (undimmed)

³ incl. optical losses and the efficiency of the operating device (converter)

⁴ incl. optical losses

Light distribution



Product drawing



SASSO 60 square downlight

ceiling
048-30106174F



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.96	0.92	0.88	0.85	0.81
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	62
B13	81
B16	98
B20	124
C10	104
C13	137
C16	168
C20	209

