

# BASO 40 opal

trimless

045-0728530H



Project / Type

Notes

Count / Date



## General

Ceiling , Recessed

aluminium raw

2210 lm/m

IP20

5310 lm

## LED

3000 K

CRI  $\geq$  80

L90 / 50000 h

initial MacAdam  $\leq$  3 SDCM

MR 0.54

MDER 0.49

## Optical

High Performance Opal

opal (lambertsch)

PstLM  $\leq$  1.0<sup>1</sup>

SVM  $\leq$  0.4<sup>1</sup>

## Electrical

DALI-2

220-240 V

system 55 W

PC1

system 97 lm/W<sup>2</sup>

1 DALI Addr.

23 W/m

## Physical

trimless

length 2420 mm

width 40 mm

height 75 mm

3.6 kg

## Cutout

length 2408 mm

width 48 mm

min. ceiling thickness 8 mm


max. ceiling thickness 20 mm

recessed depth 76 mm


<sup>1</sup> Value of containing product at full load (undimmed)

<sup>2</sup> incl. optical losses and the efficiency of the operating device (converter)

## Light distribution



## Product drawing



## Installation instructions



## Lighting calculator



# BASO 40 opal

trimless

045-0728530H



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	7
B13	10
B16	12
B20	14
C10	10
C13	20
C16	24
C20	28