

# MINO 60 CIRCLE 1000

direct / indirect

suspended

034-2413638H



Project / Type

Notes

Count / Date



## General

Ceiling , Suspended

black , RAL 9005 <sup>1</sup>

IP20

indirect 3430 lm

direct 7480 lm

total 10910 lm

## LED

4000 K

CRI  $\geq$  80

L90 / 50000 h

initial MacAdam  $\leq$  3 SDCM

MR 0.72

MDER 0.65

## Optical

High Performance Opal

opal (lambertsch)

PstLM  $\leq$  1.0<sup>2</sup> <sup>3</sup>

SVM  $\leq$  0.4<sup>2</sup> <sup>3</sup>

## Electrical

DALI-2

220-240 V

system 71 W

system 154 lm/W<sup>4</sup>

PC1

5 DALI Addr.

## Physical

cable 1500 mm / canopy central

diameter 1060 mm

height 80 mm

centerline radius 500 mm


9 kg

<sup>1</sup> RAL code <sup>2</sup> combined


<sup>3</sup> Value of containing product at full load (undimmed)

<sup>4</sup> FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

## Light distribution



## Product drawing



\*canopy central version



# MINO 60 CIRCLE 1000

## direct / indirect

suspended  
034-2413638H



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_

### Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

### Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	3
B13	5
B16	6
B20	7
C10	6
C13	8
C16	10
C20	12

### Acoustic accessories

#### MINO CIRCLE ACOUSTIC 1000 inlay

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
marble grey	937	034-270111D
black	937	034-270111L
white	937	034-270111W

