

# MINO 60 CIRCLE 1000

direct / indirect

suspended

034-2413637H



Project / Type

Notes

Count / Date



## General

Ceiling , Suspended

white , RAL 9010 <sup>1</sup>

IP20

indirect 3430 lm

direct 7480 lm

total 10910 lm

## LED

4000 K

CRI  $\geq$  80

L90 / 50000 h

initial MacAdam  $\leq$  3 SDCM

MR 0.72

MDER 0.65

## Optical

High Performance Opal

opal (lambertsch)

PstLM  $\leq$  1.0<sup>2 3</sup>

SVM  $\leq$  0.4<sup>2 3</sup>

## Electrical

DALI-2

220-240 V

system 71 W

system 154 lm/W<sup>4</sup>

PC1

5 DALI Addr.

## Physical

cable 1500 mm / canopy central

diameter 1060 mm

height 80 mm

centerline radius 500 mm


9 kg

<sup>1</sup> RAL code <sup>2</sup> combined


<sup>3</sup> Value of containing product at full load (undimmed)

<sup>4</sup> FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

## Light distribution



## Product drawing



\*canopy central version



[034-2413637H] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of XAL GmbH apply.  
© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com

06.04.2025

# MINO 60 CIRCLE 1000

## direct / indirect

suspended  
034-2413637H



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_

### Maintenance Factors

| Operating Time [h] | 10 000                       | 20 000 | 30 000            | 40 000                          | 50 000 |
|--------------------|------------------------------|--------|-------------------|---------------------------------|--------|
| LLMF               | 0.98                         | 0.96   | 0.94              | 0.92                            | 0.9    |
| LSF                | 1                            | 1      | 1                 | 1                               | 1      |
| MF                 | LMF × RSMF × LLMF × LSF      |        | RSMF <sup>a</sup> | Room Surface Maintenance Factor |        |
| MF                 | Maintenance Factor           |        | LLMF              | Lamp Lumens Maintenance Factor  |        |
| LMF <sup>a</sup>   | Luminaire Maintenance Factor |        | LSF               | Lamp Survival Faktor            |        |

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

### Circuit Breaker Types

| Automatic Circuit Breaker Type | Number of Fixtures |
|--------------------------------|--------------------|
| B10                            | 3                  |
| B13                            | 5                  |
| B16                            | 6                  |
| B20                            | 7                  |
| C10                            | 6                  |
| C13                            | 8                  |
| C16                            | 10                 |
| C20                            | 12                 |

### Acoustic accessories

#### MINO CIRCLE ACOUSTIC 1000 inlay

| COLOUR      | Ø (MM) | ARTICLE NUMBER(S) |
|-------------|--------|-------------------|
| marble grey | 937    | 034-270111D       |
| black       | 937    | 034-270111L       |
| white       | 937    | 034-270111W       |

