

MINO 60 CIRCLE 1500

direct / indirect

suspended

034-241163XH



Project / Type _____

Notes _____

Count / Date _____



General

Ceiling , Suspended _____

special colours , RAL5014 ¹ _____

IP20 _____

indirect 5490 lm _____

direct 12000 lm _____

total 17500 lm _____

LED

4000 K _____

CRI ≥ 80 _____

L90 / 50000 h _____

photobio. safety RG 0 - no Risk _____

initial MacAdam ≤ 3 SDCM _____

MR 0.72 _____

MDER 0.65 _____

Optical

High Performance Opal _____

opal (lambertsch) _____

PstLM ≤ 1.0 ² _____

SVM ≤ 0.4 ² _____

Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; suspended luminaire with 1500mm cable suspension (canopy central); with integrated tool-less suspension height adjustment; incl. feed (white); surface special colours powder coated; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; HPO (High Performance Opal) cover for uniform illumination; direct/indirect light emission for additional accentuation of the ceiling; indirect light component with special PCBs for increased luminous flux and maximum ceiling illumination; degree of protection IP20; PC1 220-240V; photobiological safety according to IEC 62471 risk group RG 0 - no Risk; internal wiring in light halogen free; incl. DALI-2 converter; sound absorbing accessories available; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Electrical

DALI-2 _____

114 W _____

PC1 220-240V _____

154 lm/W _____

5 DALI Addr. _____

Physical

cable 1500 mm / canopy central _____

diameter 1560 mm _____


height 80 mm _____

centerline radius 750 mm _____


14 kg _____

¹ RAL code ² Value of containing product at full load (undimmed)

Light distribution



Product drawing



Installation instructions



Lighting calculator



MINO 60 CIRCLE 1500

direct / indirect

suspended
034-241163XH



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	3
B13	4
B16	5
B20	7
C10	6
C13	7
C16	9
C20	11

Acoustic accessories

MINO CIRCLE ACOUSTIC 1500 inlay

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
marble grey	1434	034-270211D
black	1434	034-270211L
white	1434	034-270211W

