

MINO 60 CIRCLE 1500

direct

suspended

034-241063GZ



Project / Type

Notes

Count / Date



General

Ceiling , Suspended

grey , RAL 9006 ¹

IP20

10400 lm

LED

4000 K

CRI \geq 80

L90 / 50000 h

initial MacAdam \leq 3 SDCM

MR 0.72

MDER 0.65

Optical

Microprismatic

microprismatic

PstLM \leq 1.0^{2 3}

SVM \leq 0.4^{2 3}

Electrical

DALI-2

220-240 V

system 83 W

system 125 lm/W⁴

PC1

4 DALI Addr.

Physical

cable 1500 mm / canopy central

diameter 1560 mm

height 80 mm

centerline radius 750 mm

13 kg

¹ RAL code ² combined


³ Value of containing product at full load (undimmed)

⁴ FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.




Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; suspended luminaire with 1500mm cable suspension (canopy central); with integrated toolless suspension height adjustment on the luminaire; incl. feed (white); surface grey powder coated; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 4000 K; binning initial MacAdam \leq 3 SDCM; CRI \geq 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; micro prismatic PMMA diffuser incl. diffuser film for homogeneous illumination and reduced luminance; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. DALI-2 converter; sound absorbing accessories available; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



*canopy central version

Installation instructions



Lighting calculator



[034-241063GZ] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of XAL GmbH apply.
© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com

04.04.2025

MINO 60 CIRCLE 1500

direct

suspended

034-241063GZ



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	4
B13	5
B16	7
B20	8
C10	7
C13	9
C16	11
C20	14

Acoustic accessories

MINO CIRCLE ACOUSTIC 1500 inlay

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
marble grey	1434	034-270211D
black	1434	034-270211L
white	1434	034-270211W

