

MINO 60 CIRCLE 1000

direct

suspended

034-221263XH



Project / Type

Notes

Count / Date



General

Ceiling , Suspended

special colours , RAL5014 ¹

IP20

7480 lm

LED

4000 K

CRI \geq 80

L90 / 50000 h

photobio. safety RG 0 - no Risk

initial MacAdam \leq 3 SDCM

MR 0.72

MDER 0.65

Optical

High Performance Opal

opal (lambertsch)

PstLM \leq 1.0 ²

SVM \leq 0.4 ²

Electrical

DALI-2

system 53 W

PC1 220-240V

system 141 lm/W³

4 DALI Addr.

Physical

cable 1500 mm

diameter 1060 mm


height 80 mm

centerline radius 500 mm


8.4 kg

Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; suspended luminaire with 1500mm cable suspension; with integrated toolless suspension height adjustment on the luminaire; incl. feed (white); surface special colours powder coated; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 4000 K; binning initial MacAdam \leq 3 SDCM; CRI \geq 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; HPO (High Performance Opal) cover for uniform illumination; degree of protection IP20; PC1 220-240V; photobiological safety according to IEC 62471 risk group RG 0 - no Risk; internal wiring in light halogen free; incl. DALI-2 converter; sound absorbing accessories available; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. optical losses and the efficiency of the operating device (converter)

Installation instructions



Lighting calculator



MINO 60 CIRCLE 1000

direct

suspended

034-221263XH



Project / Type

Notes

Count / Date

Maintenance Factors

| Operating Time [h] | 10 000 | 20 000 | 30 000 | 40 000 | 50 000 |
|--------------------|--------|--------|--------|--------|--------|
| LLMF | 0.98 | 0.96 | 0.94 | 0.92 | 0.9 |
| LSF | 1 | 1 | 1 | 1 | 1 |

| | | | |
|------------------|------------------------------|-------------------|---------------------------------|
| MF | LMF × RSMF × LLMF × LSF | RSMF ^a | Room Surface Maintenance Factor |
| MF | Maintenance Factor | LLMF | Lamp Lumens Maintenance Factor |
| LMF ^a | Luminaire Maintenance Factor | LSF | Lamp Survival Faktor |

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

| Automatic Circuit Breaker Type | Number of Fixtures |
|--------------------------------|--------------------|
| B10 | 4 |
| B13 | 5 |
| B16 | 7 |
| B20 | 8 |
| C10 | 7 |
| C13 | 9 |
| C16 | 11 |
| C20 | 14 |

Acoustic accessories

MINO CIRCLE ACOUSTIC 1000 inlay

| COLOUR | Ø (MM) | ARTICLE NUMBER(S) |
|-------------|--------|-------------------|
| marble grey | 937 | 034-270111D |
| black | 937 | 034-270111L |
| white | 937 | 034-270111W |

