

# MINO 60 CIRCLE 1000

direct

suspended

034-2212538H



Project / Type

Notes

Count / Date



## General

Ceiling , Suspended

black , RAL 9005 <sup>1</sup>

IP20

6570 lm

## LED

3000 K

CRI  $\geq$  80

L90 / 50000 h

initial MacAdam  $\leq$  3 SDCM

MR 0.56

MDER 0.51

## Optical

High Performance Opal

opal (lambertsch)

PstLM  $\leq$  1.0<sup>2 3</sup>

SVM  $\leq$  0.4<sup>2 3</sup>

## Electrical

DALI-2

220-240 V

system 53 W

system 124 lm/W<sup>4</sup>

PC1

4 DALI Addr.

## Physical

cable 1500 mm

diameter 1060 mm

height 80 mm

centerline radius 500 mm


7.4 kg

<sup>1</sup> RAL code <sup>2</sup> combined


<sup>3</sup> Value of containing product at full load (undimmed)

<sup>4</sup> FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

## Light distribution



## Product drawing



# MINO 60 CIRCLE 1000

direct

suspended

034-2212538H



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	4
B13	5
B16	7
B20	8
C10	7
C13	9
C16	11
C20	14

## Acoustic accessories

### MINO CIRCLE ACOUSTIC 1000 inlay

COLOUR	Ø (MM)	ARTICLE NUMBER(S)
marble grey	937	034-270111D
black	937	034-270111L
white	937	034-270111W

