

MINO 60 CIRCLE 1500

direct / indirect

suspended
034-221153GZ



Project / Type _____

Notes _____

Count / Date _____



General

Ceiling , Suspended _____

grey , RAL 9006 ¹ _____

IP20 _____

indirect 4820 lm _____

direct 9130 lm _____

total 13950 lm _____

LED

3000 K _____

CRI ≥ 80 _____

L90 / 50000 h _____

initial MacAdam ≤ 3 SDCM _____

MR 0.56 _____

MDER 0.51 _____

Optical

Microprismatic _____

microprismatic _____

UGR < 19 _____

PstLM ≤ 1.0^{2 3} _____

SVM ≤ 0.4^{2 3} _____

Ring-shaped light fitting in rolled and seamlessly welded extruded aluminium profile; suspended luminaire with 1500mm cable suspension; with integrated toolless suspension height adjustment on the luminaire; incl. feed (white); surface grey powder coated; LED light inset consisting of highly reflective lacquered aluminium for improved thermal management; light colour 3000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; micro prismatic PMMA diffuser incl. diffuser film for homogeneous illumination and reduced luminance; direct/indirect light emission for additional accentuation of the ceiling; indirect light component with special PCBs for increased luminous flux and maximum ceiling illumination; degree of protection IP20; PC1; 220-240 V; internal wiring in light halogen free; incl. DALI-2 converter; sound absorbing accessories available; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Electrical

DALI-2 _____

220-240 V _____

system 114 W _____

system 122 lm/W⁴ _____

PC1 _____

5 DALI Addr. _____

Physical

cable 1500 mm _____


diameter 1560 mm _____

height 80 mm _____


centerline radius 750 mm _____

13 kg _____

Light distribution



Product drawing



¹ RAL code ² combined
³ Value of containing product at full load (undimmed)
⁴ FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

Installation instructions



Lighting calculator

