

# POWER SUPPLY SUSPENDED

058-6592317



Project / Type \_\_\_\_\_

Notes \_\_\_\_\_

Count / Date \_\_\_\_\_



**General**  
traffic white , RAL 9016 <sup>1</sup> \_\_\_\_\_

**Electrical**  
non DIM \_\_\_\_\_  
PC2 \_\_\_\_\_  
150 W \_\_\_\_\_  
non DIM \_\_\_\_\_  
min 176 V \_\_\_\_\_  
max 264 V \_\_\_\_\_  
η 92 % \_\_\_\_\_  
Constant Voltage \_\_\_\_\_  
min 50 Hz \_\_\_\_\_  
max 60 Hz \_\_\_\_\_

**Physical**  
suspended \_\_\_\_\_

<sup>1</sup> RAL code



# POWER SUPPLY SUSPENDED

058-6592317



Project / Type

Notes

Count / Date

### Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Converters
B13	6
B16	8
B20	10
C13	10
C16	13
C20	15

