

TASK sensor direct / indirect soft

free standing double
X059-2963177Z



Project / Type


Notes

Count / Date




Free standing luminaire with two rectangular luminaire head made of aluminium and rounded edges; luminaire heads arranged parallel; ultra low-profile design (only 15 mm); rectangular downpipe; pedestal with recess for table base (U-shape); surface white powder coated; direct/indirect light distribution by LGP body (Light Guiding Prism); side coupled light, directed up and down by laser engraving; microprismatic PMMA cover; completely homogeneous illumination; UGR ≤ 19 ; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90 ; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC1; 220-240 V; luminaire with integrated infrared presence and brightness sensor (ESSENTIAL sensor); automatic light control for individually adjustable brightness; variable automatic shutdown; including TOUCH DIM control for individual control of the brightness; presence sensor detection range $\varnothing 4,5\text{m}$ on the floor; incl. connection cable (3m) with safety plug; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



General

Floor , Standing

white , RAL 9010 ¹

IP20

indirect 7140 lm

direct 8760 lm

total 15900 lm

LED

4000 K

CRI ≥ 90

L90 / 50000 h

initial MacAdam ≤ 3 SDCM

R_g: 96 , R_f: 90 , R_{t(1-15)}: 87

MR 0.75

MDER 0.68

Optical

Microprismatic

microprismatic

UGR < 19

P_{stLM} $\leq 1.0^{2\ 3}$

SVM $\leq 0.4^{2\ 3}$

Electrical

ESSENTIAL sensor (brightness & presence)

220-240 V

system 143 W

system 111 lm/W⁴

PC1

Physical

U-shape

length 800 mm

width 940 mm

height 2054 mm

12.4 kg

¹ RAL code ² combined
³ Value of containing product at full load (undimmed)
⁴ FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

Installation instructions



TASK sensor direct / indirect soft

free standing double
X059-2963177Z



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.97	0.95	0.93	0.92
LSF	1	1	1	1	1

MF

LMF × RSMF × LLMF × LSF

MF

Maintenance Factor

LMF^a

Luminaire Maintenance Factor

RSMF^a

Room Surface Maintenance Factor

LLMF

Lamp Lumens Maintenance Factor

LSF

Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	4
B13	6
B16	7
B20	9
C10	7
C13	10
C16	12
C20	15

