

TASK sensor direct / indirect soft

free standing double long
X059-2903076Z



Project / Type _____

Notes _____

Count / Date _____



General

Floor , Standing _____
grey , RAL 9006 ¹ _____
IP20 _____
indirect 6690 lm _____
direct 8210 lm _____
total 14900 lm _____

LED

3000 K _____
CRI ≥ 90 _____
L90 / 50000 h _____
initial MacAdam ≤ 3 SDCM _____
R_g: 96 , R_f: 90 , R_{f(1-15)}: 90 _____
MR 0.61 _____
MDER 0.56 _____

Optical

Microprismatic _____
microprismatic _____
UGR < 19 _____
P_{stLM} ≤ 1.0² ³ _____
SVM ≤ 0.4² ³ _____

Electrical

ESSENTIAL sensor (brightness & presence) _____
220-240 V _____
system 143 W _____
system 104 lm/W⁴ _____
PC1 _____

Physical

H-shape _____
length 1750 mm _____
width 320 mm _____
height 2137 mm _____
12.1 kg _____


¹ RAL code ² combined

³ Value of containing product at full load (undimmed)


⁴ FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

Free standing luminaire with two rectangular luminaire head made of aluminium and rounded edges; luminaire heads arranged linear; ultra low-profile design (only 15 mm); rectangular downpipe; pedestal with recess for table base (H-shape); surface grey powder coated; direct/indirect light distribution by LGP body (Light Guiding Prism); side coupled light, directed up and down by laser engraving; microprismatic PMMA cover; completely homogeneous illumination; UGR ≤ 19; light colour 3000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; degree of protection IP20; PC1; 220-240 V; luminaire with integrated infrared presence and brightness sensor (ESSENTIAL sensor); automatic light control for individually adjustable brightness; variable automatic shutdown; including TOUCH DIM control for individual control of the brightness; presence sensor detection range ø4,5m on the floor; incl. connection cable (3m) with safety plug; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

Light distribution



Product drawing



Installation instructions



TASK sensor direct / indirect soft

free standing double long
X059-2903076Z



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.97	0.95	0.93	0.92
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	4
B13	6
B16	7
B20	9
C10	7
C13	10
C16	12
C20	15