

# MINO 60 high lumen

ceiling offset

046-47M2637H



Project / Type	
Notes	
Count / Date	



## General

Ceiling , Surface	
white , RAL 9010 <sup>1</sup>	
IP20	
Ball impact resistant DIN 18032-3	
1520 lm	
2660 lm/m	

## LED

4000 K	
CRI ≥ 80	
L90 / 50000 h	
initial MacAdam ≤ 3 SDCM	
MR 0.72	
MDER 0.65	

## Optical

High Performance Opal	
opal (lambertsch)	
PstLM ≤ 1.0 <sup>2</sup>	
SVM ≤ 0.4 <sup>2</sup>	


## Electrical

DALI-2	
220-240 V	
system 12.1 W	
system 126 lm/W <sup>3</sup>	
PC1	
1 DALI Addr.	
21 W/m	


## Physical

length 575 mm	
width 60 mm	
height 90 mm	
1.75 kg	

## Light distribution



## Product drawing



<sup>1</sup> RAL code <sup>2</sup> Value of containing product at full load (undimmed)  
<sup>3</sup> FIXTURE: incl. consideration of optical losses & internal control unit losses SYSTEM: incl. consideration of optical losses, internal control unit losses & operating device efficiency.

## Installation instructions



## Lighting calculator



# MINO 60 high lumen

ceiling offset  
046-47M2637H



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF

LMF × RSMF × LLMF × LSF

MF

Maintenance Factor

LMF<sup>a</sup>

Luminaire Maintenance Factor

RSMF<sup>a</sup>

Room Surface Maintenance Factor

LLMF

Lamp Lumens Maintenance Factor

LSF

Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	18
B13	23
B16	28
B20	35
C10	30
C13	38
C16	46
C20	58

