

# SASSO 60 round downlight

suspended

048-31705311W



Project / Type

Notes

Count / Date



## General

Ceiling , Suspended  
black , RAL9005/black <sup>1</sup>  
Inner colour black  
IP20  
854 lm

## LED

3000 K  
CRI  $\geq$  90  
L80 / 50000 h  
initial MacAdam  $\leq$  2 SDCM  
R<sub>g</sub>: 100 , R<sub>f</sub>: 91 , R<sub>f(1-15)</sub>: 88  
MR 0.59  
MDER 0.53

## Optical

wide flood  
beam angle 55°  
 $\geq$ 65° <1500 cd/m<sup>2</sup>

## Electrical


DALI-2  
10.4 W  
PC1 220-240V  
82 lm/W  
1 DALI Addr.

## Physical


diameter 72 mm  
height 150 mm

Cylindrical spotlight in die-cast aluminium; surface black (housing/light inset); pendant fitting with 1500mm suspension, incl. feed (black), can be individually shortened; passive cooling of the LEDs through improved heat sink geometry; with COB (Chip on Board) technology for maximum efficiency; no appearance of multiple shadows; light colour 3000 K; binning initial MacAdam  $\leq$  2 SDCM; CRI  $\geq$  90; min. 80% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; incl. high quality lens system; precise radiation characteristic with 55° beam; degree of protection IP20; PC1 220-240V; incl. DALI-2 converter; flicker-free visual comfort through analogue current control (minimum value 1%); converter included in canopy; canopy for through wiring; light source replaceable by an authorized professional; control gear replaceable by an authorized professional;

## Light distribution



## Product drawing



<sup>1</sup> RAL code

## Installation instructions



## Lighting calculator



# SASSO 60 round downlight

suspended

048-31705311W



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.96	0.92	0.88	0.85	0.81
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	40
B13	50
B16	65
B20	85
C10	70
C13	80
C16	104
C20	130