

# SASSO 60 square downlight

ceiling

048-30104319W



Project / Type

Notes

Count / Date



## General

Ceiling , Surface

black , RAL9005/gold <sup>1</sup>

Inner colour gold

IP20

836 lm

## LED

2700 K

CRI ≥ 90

L80 / 50000 h

initial MacAdam ≤ 2 SDCM

R<sub>g</sub>: 99 , R<sub>r</sub>: 91 , R<sub>t(1-15)</sub>: 89

MR 0.53

MDER 0.48

## Optical

wide flood

beam angle 52°

UGR < 19 , ≥65° <1500 cd/m<sup>2</sup>

## Electrical

DALI-2

system 10.4 W

PC1 220-240V

system 80 lm/W<sup>2</sup>

inset 95 lm/W<sup>3</sup>

1 DALI Addr.

## Physical

length 72 mm

width 72 mm

height 108 mm


0.5 kg

<sup>1</sup> RAL code

<sup>2</sup> incl. optical losses and the efficiency of the operating device (converter)

<sup>3</sup> incl. optical losses

## Light distribution



## Product drawing



## Installation instructions



## Lighting calculator



# SASSO 60 square downlight

ceiling  
048-30104319W



Project / Type

Notes

Count / Date

## Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.96	0.92	0.88	0.85	0.81
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

<sup>a</sup> According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

## Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	40
B13	50
B16	65
B20	85
C10	70
C13	80
C16	104
C20	130

