

GIRA wallwasher/floor

MOVE IT 10
030-6430537W



Project / Type

Notes

Count / Date



General

Ceiling , Track

rotation 360°

traffic white , RAL 9016 ¹

IP20

1480 lm

optical inset 87 lm/W²

LED

3000 K

CRI ≥ 90

L70 / 50000 h

initial MacAdam ≤ 3 SDCM

R_g: 101 , R_r: 91 , R₍₁₋₅₎: 89

MR 0.59

MDER 0.53

Optical

wallwasher floor

PstLM ≤ 1.0 ³

SVM ≤ 0.4 ³

Electrical

DALI-2

48 V

fixture 18.8 W

optical inset 16.9 W

PC3

1 DALI Addr.

Physical

length 217 mm


width 19 mm

height 19 mm


¹ RAL code
² OPTICAL INSET: incl. consideration of optical losses
³ Value of containing product at full load (undimmed)

Linear light inset made of aluminium; surface traffic white powder coated; light inset 360° rotatable; light inset can be installed and moved without tools by means of clip mount; power supplied via MOVE IT system track profile; hot plug protection; fitted with single LED light points; passive cooling of the LEDs through improved heat sink geometry; light colour 3000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90; min. 70% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; good glare control through recessed light point level; with specially computed, asymmetrical reflector for homogeneous lighting intensity; degree of protection IP20; PC3; 48 V; DALI-2 control; flicker-free visual comfort through analogue current control (minimum value 1%); light source replaceable by an authorized professional;

Light distribution



Product drawing



Installation instructions



Lighting calculator



GIRA wallwasher/floor

MOVE IT 10
030-6430537W



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.936	0.89	0.847	0.806	0.767
LSF	1	1	1	1	1

MF

MF

LMF^a

LMF × RSMF × LLMF × LSF

Maintenance Factor

Luminaire Maintenance Factor

RSMF^a

LLMF

LSF

Room Surface Maintenance Factor

Lamp Lumens Maintenance Factor

Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

