

MINO 60 S CIRCLE

1500 direct / indirect

suspended
034-741163GH



Project / Type	
Notes	
Count / Date	



General

Ceiling , Suspended
grey , RAL9006 ¹
IP20
indirect 5800 lm
direct 10300 lm
total 16100 lm

LED

4000 K
CRI ≥ 80
L90 / 50000 h
photobio. safety RG 0 - no Risk
initial MacAdam ≤ 3 SDCM
MR 0.72
MDER 0.65

Optical

High Performance Opal
PstLM ≤ 1.0 ²
SVM ≤ 0.4 ²

Electrical


DALI-2
119 W
PC1 220-240V
135 lm/W
5 DALI Addr.

Physical


cable 1500 mm / canopy central
diameter 1560 mm
height 60 mm
centerline radius 750 mm
14 kg

¹ RAL code ² Value of containing product at full load (undimmed)

Light distribution



Product drawing



Lighting calculator



[034-741163GH] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of XAL GmbH apply.
© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com

03.07.2024

MINO 60 S CIRCLE

1500 direct / indirect

suspended
034-741163GH



Project / Type _____

Notes _____

Count / Date _____

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	3
B13	4
B16	5
B20	7
C10	6
C13	8
C16	10
C20	12

