

MINO 60 S CIRCLE

1500 direct / indirect

suspended

034-7411637H



Project / Type
Notes
Count / Date



General

Ceiling , Suspended
white , RAL9010 ¹
IP20
indirect 5800 lm
direct 10300 lm
total 16100 lm

LED

4000 K
CRI ≥ 80
L90 / 50000 h
photobio. safety RG 0 - no Risk
initial MacAdam ≤ 3 SDCM
MR 0.72
MDER 0.65

Optical

High Performance Opal
opal (lambertsch)
PstLM ≤ 1.0 ²
SVM ≤ 0.4 ²

Electrical


DALI-2
system 119 W
PC1 220-240V
system 135 lm/W ³
5 DALI Addr.

Physical


cable 1500 mm / canopy central
diameter 1560 mm
height 60 mm
centerline radius 750 mm
14 kg

¹ RAL code ² Value of containing product at full load (undimmed)
³ incl. optical losses and the efficiency of the operating device (converter)

Light distribution



Product drawing



Installation instructions



Lighting calculator



MINO 60 S CIRCLE

1500 direct / indirect

suspended
034-7411637H



Project / Type

Notes

Count / Date

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.96	0.94	0.92	0.9
LSF	1	1	1	1	1
MF	LMF × RSMF × LLMF × LSF		RSMF ^a	Room Surface Maintenance Factor	
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor	
LMF ^a	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor	

^a According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	3
B13	4
B16	5
B20	7
C10	6
C13	8
C16	10
C20	12

