

# POWER SUPPLY SUSPENDED

058-6592218



Projet / Type \_\_\_\_\_

Notes \_\_\_\_\_

Quantité / Date \_\_\_\_\_



**Général**  
noir profond , RAL 9005 <sup>1</sup> \_\_\_\_\_

**Electrique**  
non DIM \_\_\_\_\_  
CP2 \_\_\_\_\_  
100 W \_\_\_\_\_  
non DIM \_\_\_\_\_  
min 176 V \_\_\_\_\_  
max 264 V \_\_\_\_\_  
η 92 % \_\_\_\_\_  
Tension Constante \_\_\_\_\_  
min 50 Hz \_\_\_\_\_  
max 60 Hz \_\_\_\_\_

**Physique**  
Suspensions \_\_\_\_\_

<sup>1</sup> Code RAL



# POWER SUPPLY SUSPENDED

058-6592218



Projet / Type

Notes

Quantité / Date

## Types de disjoncteurs

Type de disjoncteur automatique	Nombre de convertisseurs
B13	8
B16	10
B20	12
C13	13
C16	17
C20	20

